

F21-1182

8466608



شركة العارف المقاولات ش.م.م.
AL-ARIF CONTRACTING CO. (S.C.)



DOCUMENT TRANSMITTAL FORM (DTF)

Contract No:

Work Package:

TO: KHATIB & ALAMI

TRANS. NO: TH01-PH1-ACC-KAA-MAT-ARCH-5726

FROM: AL-ARIF CONTRACTING CO.

DATE: 16/08/2020

ATTN: ENG. AHMED ABULAZM

C/REF: 0

WE ARE SENDING:		SUBMITTED FOR:		ACTION TAKEN:	
<input type="checkbox"/>	Documents	<input checked="" type="checkbox"/>	Approval	<input type="checkbox"/>	A -Approved
<input type="checkbox"/>	Drawings/Sketch	<input type="checkbox"/>	Review & Comments	<input type="checkbox"/>	B -Approved as noted, Incorporate Comments
<input type="checkbox"/>	PREQ.	<input type="checkbox"/>	As Requested	<input type="checkbox"/>	C- Approved with Comments, Revise & Re-submit
<input type="checkbox"/>	Change Order	<input type="checkbox"/>	Information / Records Only	<input type="checkbox"/>	D- Rejected
<input type="checkbox"/>	Letter	<input type="checkbox"/>	For Necessary Action	<input type="checkbox"/>	N- Noted
<input type="checkbox"/>	Invoice	<input type="checkbox"/>	Other:	<input type="checkbox"/>	
<input type="checkbox"/>	SHD				
<input type="checkbox"/>	BOQ/Specification	SENT VIA:		<input type="checkbox"/>	R- Reviewed as Compliant
<input checked="" type="checkbox"/>	MATERIAL SUBMITTAL	<input checked="" type="checkbox"/>	Attached	<input type="checkbox"/>	S- Reviewed as Noted, Incorporate comments
		<input type="checkbox"/>	Separate Cover	<input type="checkbox"/>	T- Reviewed with comments, Revise & Re-submit


Item No.	Submittal or Document No.	Rev No.	Date	Description of Submittal or Document Title	Copies
1	TH01-PH1-ACC-KAA- MAT- ARCH-5726	00	16/08/2020	BUILDING: A59-60-61 Polystyrene Skirting From Arch Deco Gym Areas (Client approval attached)	3+CD
				Sample attached	
			Supplier	Arch Deco	

Response:

Approval Status:

B

Item No.	Submittal or Document Ref. No.	Rev	Date	Description of Submittal or Document Title	Status



Sender Name:

ENG. AHMED FOUAD

Designation:

Signed by Sender

Handwritten signature and date: 16/8/2020

Title

*Legends: A- Approved B- Approved As Noted, Incorporate Comments C- Approved With Comments, Revise & Resubmit D- Rejected R- Reviewed As Compliant S-Reviewed As Noted, Incorporate Comments T-Reviewed with comments, Revise & Resubmit N- Noted

SUBMITTAL REVIEW COMMENTS FORM

REVIEW BY: DESIGN CONSULTANT SUPERVISION CONSULTANT OTHER (Specify)

TYPE OF SUBMITTAL: **Material Submittal** SUBMITTAL NO.: TH01-PH1-ACC-KAA-MAT-ARCH-5726 TRANSMITTAL NO.: TH01-PH1-ACC-KAA-MAT-ARCH-5726

SUBJECT: **Building A59-60-61 Polystyrene Skirting From Arch Deco Gym Areas (Client Approval Attached)** SUB-REVIEW REF. **TH01-PH01-KAA-ACC-SRC-A0-6321** REVIEW / APPR. STATUS: **B**

Item No.	Title / Reference No. of Document Reviewed	Review Comments	Review Basis (Specify Contract / Specifications Clauses)
	<p>TH01-PH1-ACC-KAA-MAT-ARCH-5726</p> <p>Building A59-60-61 Polystyrene Skirting From Arch Deco Gym Areas (Client Approval Attached)</p> <p>DATED 17/08/2020</p>	<p>MATERIAL: Polystyrene Skirting from Arch Deco Gym Area Building : A59, A60, A61</p> <p>The above-mentioned submittal which we received via Transmittal No. TH01-PH1-ACC-KAA-ARCH-5726 dated 17.08.2020 was reviewed the proposed acceptable on condition the followings are fulfilled:</p> <p>Client/CIMS Approved above-mentioned (Polystyrene Skirting from Arch Deco Gym Area):</p> <ol style="list-style-type: none"> Selected Sample of the above mentioned is accepted both as a material and color from client /CIMS. (Attached color sample and sizes) Contractor to submit the latest test reports as per project specification (attached reports are very old - 2012). Contractor to submit the MIR for the inspection by K&A representative at the time of delivery of the above material. <p>Code "B". (Approved as Noted, incorporated with all comments).</p>	



Reviewer Company Name: **KHATIB & ALAMI**

Reviewer's Name: **Syed Farhan** Designation: **Senior Material Engineer** Signature: _____ Date: **18/8/2020**

Reviewer's Name: **Mohamad Fahed Annous** Designation: **First Lead Arch. Engineer** Signature: _____ Date: **14/08/2020**

Reviewer's Name: **Ahmad Hassan Aboul Azm** Designation: **Project Manager** Signature: _____ Date: **19/08/2020**

TITLE: BUILDING: A59-60-61 Polystyrene Skirting From Arch Deco Gym Areas (<u>Client approval attached</u>)		SUBMITTAL NO: TH01-PH1-ACC-KAA-ARCH-5726	
TO: KHATIB & ALAMI		DATE: 16/08/2020	
FROM: AL-ARIF CONTRACTING CO ACC		REVISION NO: 0	
ATTN: (ENG. HESHAM ALI)		C/REF: 0	

MATERIAL SUBMISSION DESCRIPTION

Discipline: ARCH

Description of Material	BUILDING: A59-60-61 Polystyrene Skirting From Arch Deco Gym Areas (<u>Client approval attached</u>)
Specification / Control Document Reference	
Manufacturer (Name & Address)	SHANGHAI INTCO INDUSTRIES CO. LTD
Supplier / Local Agent	Arch Deco
Description of Attachments	
Description of Samples	Sample (<u>Client approval attached</u>)
Specification Comparison Sheet	
Comparison in case of Alternative Submittal	

Submitted By Contractor's Rep.: ENG. AHMED FOUAD Signature: _____

PROJECT MANAGEMENT CONSULTANT'S REVIEW

Name: _____ Signature: _____ Date: _____

CLIENT'S (Athakher) COMMENTS (optional)

(For additional comments attach Submittal Review Comments form Ref.PSA- where applicable)

Name: _____ Signature: _____ Date: _____

SUPERVISION CONSULTANT'S COMMENTS

A-Approved
 B- Approved As Noted, Work with Material May Proceed Subject to Incorporation of Comments & Resubmittal within ... days
 C-Approved with Comments Work with Material May **NOT** Proceed, Revise & Resubmit.
 D- Rejected

(For additional comments attach Submittal Review Comments form Ref.PSA- where applicable)

DATE RECEIVED: _____ DATE RETURNED: _____

SUPERVISION CONSULTANT RESIDENT ENGINEER'S SIGNATURE

For & On behalf of (*Insert Name of Supervision Consultant*): _____

جستجو

GYM

سید علی

! سید علی

12/18/20



TEST REPORT

No. : SHMR120301587

Date : Mar.23,2012

Page: 1 of 3

SHANGHAI INTOCO INDUSTRIES CO.,LTD
1299,HUBIN RD,FENGXIAN,SHANGHAI,P.R.CHINA 201417


The following sample(s) was/ were submitted and identified on behalf of the client as:

Sample Name : PS SKIRTING BOARD
 Sample No. : SHMR120301587
 SGS Ref. No. : SP120300997
 Manufacturer : SHANGHAI INTOCO INDUSTRIES CO.,LTD
 Test Required : Flammability
 Ref. standard : UL 94 Ed.5 Oct 29, 1996 Revision Oct 21, 2010 section 8
 Date of Receipt : Mar.12,2012
 Test Period : Mar.12,2012 to Mar.23,2012

Test result(s) : For further details, please refer to the following page(s)

***** To be continued*****

Signed for SGS-CSTC Standards
Technical Services (Shanghai) Co., Ltd


 Peterson Zhang
 Authorized signatory

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its issue, and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



8th building, No.69 Block 1159 Kangqiao East Road, Pudong District, Shanghai, China 201319
 中国·上海·上海浦东康桥东路1159弄69号8号楼 邮编: 201319

t (86-21) 61196300 f (86-21) 68183920 www.cn.sgs.com
 t (86-21) 61196300 f (86-21) 68183920 e sgs.china@sgs.com

SHMR 052374

Attention: To check the authenticity of testing / inspection report & certificate, pls. contact tel: (86-25)83071443 email: CN.Doccheck@sgs.com

TEST REPORT

No. : SHMR120301587

Date : Mar.23,2012

Page: 2 of 3

Sample Description: Brown board

Specimen: 125mm×13mm×5.59mm

Test Result:

Conditioning	23±2°C, 50±5%RH, 48h					70±2°C, 168h				
	1	2	3	4	5	1	2	3	4	5
Afterflame time after first application (t ₁ ,s)	9.1	3.4	1.0	9.5	7.4	2.7	1.0	1.0	1.9	6.5
Afterflame time after second application (t ₂ ,s)	1.0	4.4	7.8	1.0	3.9	1.0	3.2	4.4	2.9	1.7
Afterglow time after second application (t ₃ ,s)	28.7	1.0	1.0	25.8	11.4	3.8	1.0	1.0	1.0	8.9
Afterflame or afterglow of any specimen up to the holding clamp	No	No	No	No	No	No	No	No	No	No
Ignition of the cotton indicator	No	No	No	No	No	No	No	No	No	No

Classification: V-0

Note: According to UL 94 Ed.5 Oct 29, 1996 Revision Oct 21, 2010 section 8, material classifications are specified as follows:

Criteria classification	V-0	V-1	V-2
Afterflame time for each individual specimen t ₁ or t ₂	≤10s	≤30s	≤30s
Total after flame time for any condition set (t ₁ plus t ₂ for the 5 specimens)	≤50s	≤250s	≤250s
Afterflame plus afterglow time for each individual specimen after the second flame application(t ₂ + t ₃)	≤30s	≤60s	≤60s
Afterflame or afterglow of any specimen up to the holding clamp	No	No	No
Cotton indicator ignited by flaming particles or drops	No	No	Yes

***** To be continued*****

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its inspection and is provided within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



SGS Standards Technical Services (Shanghai) Co., Ltd.
Testing Laboratory

8th building, No.69, Block 1159 Kangqiao East Road, Pudong District, Shanghai, China 201319
中国·上海·上海浦东康桥东路1159弄69号8号楼 邮编: 201319

t (86-21) 61196300 f (86-21) 68183920 www.cn.sgs.com
t (86-21) 61196300 f (86-21) 68183920 e sgs.china@sgs.com

SHMR 052413

Attention: To check the authenticity of testing /inspection report & certificate, pls. contact tel: (86-755)83071443 email: CN.Doccheck@sgs.com

TEST REPORT

No. : SHMR120301587

Date : Mar.23,2012

Page: 3 of 3

Sample Photo:



***** End of report *****

Attention: To check the authenticity of testing /inspection report & certificate, pls. contact tel: (86-785)103071443 email: CN.Doccheck@sgs.com

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, jurisdiction and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its inspection and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



8th building, No.69, Block 1159 Kangqiao East Road, Pudong District, Shanghai, China 201319
中国·上海·上海浦东康桥东路1159弄69号8号楼 邮编: 201319

t (86-21) 61196300
t (86-21) 61196300

f (86-21) 68183920
f (86-21) 68183920

www.cn.sgs.com
e sgs.china@sgs.com

SHMR 052414