



TEST REPORT

SCOPE OF WORK

WPC Decking

REPORT NUMBER

200609006SHF-001

TEST DATE(S)

2020-06-09 - 2020-06-28

ISSUE DATE


2020-06-28

PAGES

5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2020)



Test Report

Issue Date: 2020-06-28

Report No. 200609006SHF-001

Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	WPC Decking	Brand	/
Sample Description	Good Condition	Sample Amount	4 PCS
		Received Date	2020-06-08
Sample ID	Model	Specification	
S200609006SHF.001	/	140mm*23mm	

Test Methods And Standards

Test Standard	EN 15534-1:2014+A1:2017 Section 6.4.2 and CEN/TS 15676:2007
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Test Report

Issue Date: 2020-06-28

Report No. 200609006SHF-001

Test Items, Method and Results:

Test Item: Slipperiness (Pendulum test)

Test Method: EN 15534-1:2014+A1:2017 Section 6.4.2 and CEN/TS 15676:2007


Conditioning: At a temperature of $(23\pm 2)^{\circ}\text{C}$ and relative humidity of $(50\pm 5)\%$

Rubber Slider: Slider 55

Test Item	Test Method	Test Results
Slipperiness (Pendulum test)	EN 15534-1:2014+A1:2017 Section 6.4.2 CEN/TS 15676:2007	Wet condition Longitudinal direction: Mean: 51 Minimum: 50 Horizontal direction: Mean: 65 Minimum: 65

Note:

1. Test on the black color surface was referring to below picture.
2. Test on wet condition was required by the applicant.



Test Report

Issue Date: 2020-06-28

Report No. 200609006SHF-001

Appendix A: Sample Received Photo

